DOI: <https://doi.org/10.15407/techned2018.04 . 053>

ACTIVE FILTERS APPLICATION FOR ENERGY LOSSES REDUCTION IN THREE-PHASE POWER SUPPLY SYSTEMS

Journal	Tekhnichna elektrodynamika
Publisher	Institute of Electrodynamics National Academy of Science of Ukraine
ISSN	1607-7970 (print), 2218-1903 (online)
Issue	No 4, 2018 (July/August)
Pages	53 – 56

Authors

M.Yu. Artemenko^{1*}, V.V. Kaplun^{2}, V.M. Bobrovnyk^{2***}, S.Y. Polishchuk^{3****}**

¹ – National Technical University of Ukraine “Igor Sikorsky Kyiv Polytechnic Institute”,
pr. Peremohy, 37, Kyiv, 03056, Ukraine,
e-mail: artemenko_m_ju@ukr.net

² – Kyiv National University of Technology and Design,
Nemirovich-Danchenko Street, 2, Kyiv, 01011, Ukraine,
e-mail: kaplun.v@knutd.com.ua

³ – Institute of Electrodynamics National Academy of Science of Ukraine,
pr. Peremohy, 56, Kyiv, 03057, Ukraine

* ORCID ID : <http://orcid.org/0000-0001-9341-9238>

** ORCID ID : <http://orcid.org/0000-0001-7040-9344>

*** ORCID ID : <http://orcid.org/0000-0003-1779-5375>

**** ORCID ID : <http://orcid.org/0000-0002-6978-2747>

Abstract

A new analytical condition of expedient application of shunt active filters (SAF) and formula for estimating the energy saving effect from their installation in three-phase power supply systems under stationary load have been obtained. It is proposed to evaluate the energy-saving effect from the use of SAF under periodically varying load by the energy losses gain coefficient, for which the method of determination is given. The application of the method is illustrated by the calculation of the energy-saving effect by the results of weekly monitoring the electricity consumption in the KNUTD hostel number 7. References 9, figures 2, table 1.

Key words: power losses, shunt active filter, three-phase power supply system.

Received: 05.03.2018

Accepted: 11.04.2018

Published:

References

1. Zhemerov, G.G., Tugay, D.V. Components of total electric energy losses power in pqr spatial coordinates. *Electrical engineering & Electromechanics*. 2016. No 2. Pp. 11-19. (Rus)
2. Artemenko M., Lesyk V., Polishchuk S. Power losses in three-phase four-wire power system. *Elektronika ta zviyazok*. 2016. No 5. Pp. 25–30. (Ukr)
3. Akagi H., Watanabe E.H., Aredes M. Instantaneous power theory and applications to power conditioning. Piscataway, NJ: IEEE Press. 2007. 379p. DOI: <https://doi.org/10.1002/0470118938>
4. Czarnecki L.S. Currents' Physical Components (CPC) concept: a fundamental of Power Theory. *Przegląd Elektrotechniczny*. 2008. Vol. 84. No 6. Pp. 28-37. DOI: <https://doi.org/10.1109/ISNCC.2008.4627483>
5. Revuelta P. Salmeron, Litran S.P., Thomas J.P.. Active Power Line Conditioners Design, Simulation and Implementation for Improving Power Quality. Elsevier Inc., Academic Press.

2016. 436 p.

6. Drechsler R. Measurement and evaluation of the quality of electric power with asymmetric and non-linear load. Moskva: Energoatomizdat. 1985. 112 p. (Rus)
7. Zhemerov G.G., Ilyina O.V. Calculation of parameters of capacitive energy storage pulsation instantaneous real power. *Elektrichestvo*. 2008. No 1. Pp. 54–59. (Rus)
8. Artemenko M.Yu. Power of supply systems and energy efficiency of power filters. Kyiv: Avers, 2016. 216 p. (Ukr)
9. Kaplun V.V., Artemenko M.Yu., Bobrovnik V.M., Polishchuk S.Y. Application prospects of shunt active filters with energy storage elements to increase the energy efficiency of three-phase four-wire electrical supply systems. *Visnyk Kyivskoho Natsionalnoho Universytetu Tekhnolohii ta Dyzainu*. 2017. No 5 (114). Pp. 24–31.

[PDF](#)