DOI: <https://doi.org/10.15407/techned2020.05.045>

LOCAL AUTONOMOUS SOURCES OF ENERGY SUPPLY FOR EMERGENCIES

Journal	Tekhnichna elektrodynamika
Publisher	Institute of Electrodynamics National Academy of Science of Ukraine
ISSN	1607-7970 (print), 2218-1903 (online)
Issue	No 5, 2020 (September/October)
Pages	45 - 48

Authors

O.P. Chornyi^{1*}, Iu.V. Zachepa^{1}, L.I. Mazurenko^{2***}, S.G. Buryakovskiy^{3****}, V.V. Chenchevoi
, N.V. Zachepa¹**

1*****

1 - Kremenchuk Mykhailo Ostrohradskyi National University,
20, Pershotravneva str., Kremenchuk, 39600, Ukraine,
e-mail: alekseii.chornyi@gmail.com

2 - Institute of Electrodynamics National Academy of Sciences of Ukraine,
Peremohy, 56, Kyiv, 03057, Ukraine,

3 - Research and Design Institute "Molniya" of National Technical University "Kharkiv
Polytechnic Institute",
47, Shevchenko str., Kharkiv, 61013, Ukraine

* ORCID ID : <https://orcid.org/0000-0001-8270-3284>

** ORCID ID : <https://orcid.org/0000-0003-4364-6904>

*** ORCID ID : <https://orcid.org/0000-0002-7059-249X>

**** ORCID ID : <https://orcid.org/0000-0003-2469-7431>

***** ORCID ID : <https://orcid.org/0000-0002-6478-3767>

***** ORCID ID : <https://orcid.org/0000-0003-0365-5320>

Abstract

Dynamic modes of operation of a local autonomous energy source with the connection of the main typical consumers of electricity are investigated. The overload capacity of a local autonomous power source, formed from electrical equipment of other functional purpose on the basis of an asynchronous machine with capacitive self-excitation, is determined. The conditions

for the implementation of "favorable" switching during startup of motors of comparable power have been established and the expediency of using start-up systems and systems of pre-start boosting excitation of the electric generator in the autonomous power supply source has been substantiated. References 6, figures 3, tables 2.

Key words: autonomous power supply, starting system, generator with self-excitation.

Received: 28.02.2020

Accepted: 10.05.2020

Published: 25.08.2020

References

1. Roos F. Electricity Supply Reliability: Evaluation of Improvement Solutions for Existing Electricity Networks. Lund: Lund Institute of Technology, 2005. 113 p.
2. Bevere L. Natural catastrophes and man-made disasters in 2018: secondary perils on the frontline. Zurich: Swiss Re Institute. Sigma. 2019. No 2. 36 p. URL: https://www.swissre.com/dam/jcr:bc66752a-da35-4645-ad46-c9d1f96a8fd9/lucia_bevere_webinar_natural_catastrophes.pdf (accessed 31.01.2020)
3. Farah P.D. Sustainable Energy Investments and National Security: Arbitration and Negotiation Issues, *Journal of world energy law and business*. 2015. Vol. 8. No 6. Pp. 34-49. DOI: <https://doi.org/10.1093/jwelb/jwv036>
4. Halkos G., Managi M., Tzeremes N. The Effect of Natural and Man-made Disasters on Countries Production Efficiency. *The Journal of Economic Structures*. 2015. No 4(1). Pp. 1-13. DOI: <https://doi.org/10.1186/s40008-015-0019-2>
5. Zagirnyak M., Zachepa Iu., Chorny O., Chenchvoi V. The autonomous sources of energy supply for the liquidation of technogenic accidents. *Przegląd Elektrotechniczny*. 2019. No 95(5). Pp. 47-50. DOI: <https://doi.org/10.15199/48.2019.05.12>
6. Zagirnyak M., Zachepa Iu., Chenchvoy V. Estimation of induction generator overload capacity under connected direct current consumers. *Acta Technica*. 2014. Vol. 59. No 2. Pp. 149-169.

[PDF](#)

This work is licensed under a [Creative Commons Attribution-NonCommercial-NoDerivatives 4.0 International License](#)