

DOI: <https://doi.org/10.15407/techned2016.06.038>

IMPROVED UTILIZATION OF TAPPED AUTOTRANSFORMERS WITH THE OUTPUT COMMUTATOR AS A COMPONENT OF THE AC VOLTAGE STABILIZER

Journal	Tekhnichna elektrodynamika
Publisher	Institute of Electrodynamics National Academy of Science of Ukraine
ISSN	1607-7970 (print), 2218-1903 (online)
Issue	№ 6, 2016 (November/December)
Pages	38 – 43

Authors

K.O. Lypkivskyi, A.G. Mozharovskyi

Institute of Electrodynamics National Academy of Science of Ukraine,
pr. Peremohy, 56, Kyiv-57, 03680, Ukraine,
e-mail: lypkivskyk@ukr.net

Abstract

In order to increase the efficiency of use of the autotransformer (AT) with tapped winding as a component of the transformer-and-switches executive structures (TSES) of AC voltage stabilizers, multiphysics simulation of the AT with the semiconductor commutator at the output has been fulfilled. The TSES, in which the commutator is placed at the input of the AT, has been compared with the proposed one. The advantage of the proposed TSES for certain parameters have been proven. The possibility of influence of purposeful change of positioning of the winding sections has been tracked. References 15, figures 5, tables 3.

Key words: transformer-and-switches executive structure, tap chancing transformer, utilization efficiency of autotransformer, winding positioning.

Received: 02.06.2016

Accepted: 06.06.2016

Published: 27.10.2016

References

1. Belopolskyi I.I., Karetnikova E.I., Pikalova L.G. Calculation of low-power transformers and reactors. Moskva: Energiia, 1973. 400 p. (Rus)
2. Borisenko A.I., Kostikov O.N., Yakovlev A.I. Cooling of industrial electric machinery. Moskva: Energoatomizdat, 1983. 296 p. (Rus)
3. Lypkivskyi K.O., Mozharovskyi A.G. Simulation of the transformative elements with sectioning of the windings as part of AC voltage source converters. *Tekhnichna Elektrodynamika* . 2016. No 3. P. 39–44. (Ukr)
4. Lypkivskyi K.O. Transformer-and-Switches Executive Structures of Alternating Current Voltage Converters. Kiev: Naukova Dumka, 1983. 216 p. (Rus)
5. Podoltsev A.D., Kucheriava I.M. Multiphysics modeling in electrical engineering. Kiev: Institut Elektrodinamiki Natsionalnoi Akademii Nauk Ukrainy, 2015. 305 p. (Rus)
6. Starodubtsev Yu.N. Theory and calculation of low-power transformers. Moskva: PC RadioSoft, 2005. 320 p. (Rus)
7. Types UPS. Available at: <http://www.mos-invertor.ru/art.html> (accessed 27.05.2016).
8. Khalikov V.A. Review of the status and opportunities to improve the organization of switching processes in the power transformer and the switches nodes. *Tekhnichna Elektrodynamika* . 2012. No 5. P. 28–37. (Ukr)
9. Khnykov A.V. Theory and calculation of multiple winding transformer. Moskva: SOLON-Press, 2010. 112 p. (Rus)
10. GOST 27427.1-83 Rolled Electrical Steel. (Rus)
11. Bimal, K. Bose. Power Electronics – Why the Field is so Exciting. *IEEE Power Electronics*

Society Newsletter Fourth Quarter.

2007. Vol. 19. No 4. P. 11–20.

12. Comsol Multiphysics. <http://www.comsol.com>

13. Automatic voltage regulation technologies. Available at: <http://www.sigmaelectricals.com/autotech01.htm>
(accessed 27.05.2016).

14. IEC 62040-3 UPS Types and Methods. Available at: http://www.wilsonengineered.com/Tech/IEC_62040-3_UPS-Topology.pdf
(accessed 27.05.2016).

15. US Patent 6472851 B2, G05F1/147. Hybrid tap-changing transformer with full range of control and high resolution. Peter Hammond. 29.10.2002.

[PDF](#)