

DOI: [https://doi.org/10.15407/ techned2016.01.060](https://doi.org/10.15407/techned2016.01.060)

DETERMINATION OF REACTIVE POWER COMPENSATION MODE IN FOUR-WIRE THREE-PHASE ELECTRIC POWER SUPPLY SYSTEM USING SEARCH ENGINE OPTIMIZATION

| | |
|-----------|---|
| Journal | Tekhnichna elektrodynamika |
| Publisher | Institute of Electrodynamics National Academy of Science of Ukraine |
| ISSN | 1607-7970 (print), 2218-1903 (online) |
| Issue | Nº 1, 2016 (January/February) |
| Pages | 60 – 66 |

Authors

V.G.Yagup¹, K.V.Yagup²

¹ – Kharkiv National University of Municipal Economy,
Revolution str., 12, Kharkov, 61002, Ukraine.

e-mail: yagup_walery@mail.ru

² – Ukrainian State University of Railway Transport,
Feyerbakh sq. 7, Kharkov, 61050, Ukraine,
e-mail: kate.yag@rambler.ru

Abstract

The task of balancing and reactive power compensation in three-phase four-wire power supply system with asymmetric three-phase load is considered. The task is carried out by numerical methods using optimization and mathematical model of power supply system. The proposed efficiency function calculated by the model and based on analysis of symmetrical components of currents in power lines. Optimization parameters are the parameters of the reactive elements

of symmetry-compensating device.. The latter is formed of six generalized reactive elements, so the problem is reduced to finding a local minimum. After the end of the optimization redundant element is eliminated, and the parameters of the symmetry-compensating device can be refined. References 10, figures 4, table 1.

Key words: three-phase system, the zero wire, reactive power, compensating device, search engine optimization.

Received: 04.09.2015

Accepted: 29.10.2015

Published: 29.01.2016

References

1. Artemenko M.Yu., Batrak L.M., Mykhalskyi V.M., Polishchuk S.Y. Energy performs optimization of the three phase four wire power supply system with a parallel active filter in unbalanced sinusoidal mode.
Tekhnichna Elektrodynamika
. 2015. No 2. P. 30-37. (Ukr)
2. Venikov V.A., Glazunov A.A., Zhukov L.A. Power networks. Moskva: Vysshiaia shkola. 1971. 438 p. (Rus)
3. Milyakh A.N., Shydlovskyi A.K., Kuznetsov A.G. Balancing of circuit single-phase loads in three-phase circuits. Kyiv: Naukova Dumka, 1973. 219 p. (Rus)
4. Shydlovskyi A.K., Kuznetsov V.G. Improving energy quality in power networks. Kyiv: Naukova Dumka, 1985. 268 p.(Rus)
5. Shydlovskyi A.K., Mostoviak I.V., Kuznetsov V.G. Phase forming circuits analysis and synthesis. Kyiv: Naukova Dumka, 1979. 299 p. (Rus)
6. Shydlovskyi A.K., Novskiy V.A., Kaplychnyi N.N. Stabilization of electric energy parameters

- in distributing networks. Kyiv: Naukova Dumka, 1989. 312 p. (Rus)
7. Shydlovskyi A.K., Mostoviak I.V., Moskalenko G.A. Mode balancing of polyphase circuits . Kyiv: Naukova Dumka, 1990. 272 p. (Rus)
8. Yagup V.G., Yagup E.V. Calculation of reactive power compensation mode in the unbalanced power system by search engine optimization techniques. *Naukovi Pratsi Donetskoho Natsionalnoho Tekhnichnogo Universitetu Elektrotehnika i Energetika.* 2011. No 11 (186). P. 449-454. (Rus)
9. Yagup V.G., Yagup E.V. Synthesis of electric system in time domain by searching optimization method. *Tekhnichna Elektrodynamika.* 2015. No 2. P. 24-29. (Rus)
10. SimPowerSystems™ – Available at:
http://www.mathworks.cn/help/pdf_doc/physmod/po-wersys/ powersys.pdf

[PDF](#)